



No.: CED/SVNIT/2019-20/C-590

Date: 11/03/2020


**Condition Assessment Audit & Building Safety Certificate  
of Scholar English Academy, R S 104, Gavier, Surat Dumas  
Road, Surat – 395 007**


Prof A J Shah (Associate Professor) from Civil Engineering Department visited to Scholar English Academy, R S 104, Gavier, Surat Dumas Road, Surat – 395 007 on dated 09/03/2020. The purpose of the visit is to review the condition Assessment and Stability of the building. During site visit survey visual inspections were carried out and Non-destructive Test conducted on the vertical load carrying elements (Columns). The building consists of RCC structure having Ground plus two stories. The building was constructed in the year 2005 (approximately 15 year before) as per the information given by the concern school authority. Regular maintenance of building seems to be good.

It is found that the condition of the concern school building structure is safe and stable for its intended use subjected to following conditions.


- The undersigned SVNIT Team will not be responsible for any alteration in design, Extra construction on existing structure and changes in structural elements of the building.
- The present condition of the structure does not include any extreme man-made and natural calamities like severe flood, Earthquake & hurricane).

Regular maintenance and Condition Assessment must be carried out every year.

  
(Prof. A J Shah) 12/3/2020  
M.E. (Structural Engineering),  
Associate Professor  
Civil Engineering Department  
SVNIT, Surat



Forwarded through

  
12/3/2020

Professor & Head, CED